

**ADDENDUM NO. #0**

**TENNIS COURTS**

LITTLE JOB #612-12353-05

DSA: A# 03-120287 File #56-H4

**Channel Islands High School**

1400 Raiders Way.  
Oxnard, CA 93033

April 17, 2020

**LITTLE**

1300 Dove Street, Suite 100  
Newport Beach, CA 92660



Architect- Jay R. Tittle, C- 12955

**1. PART 1 - GENERAL**

**1.1.** The following revisions and/or clarifications shall be made to the Bidding Requirements and Contract Documents. Revise and amend the Documents for the above named project in accordance with this Addendum. The bid shall reflect these addendum changes and each bidder shall make reference in their bid to this addendum.

**1.2.** All Bidding Requirements and Contract Documents shall apply to this addendum as originally indicated in the applicable portions of the contract documents, unless otherwise modified by this addendum.

**1.2.1.** None.

**1.3. GENERAL CLARIFICATIONS**

**1.3.1.** The following clarifications are issued to all bidders as information for use in preparing bids:

**1.3.1.1.** The intent of this Addendum is to define the scope of work for this bid, and therefore have noted 'Not in Contract' for those plans and specification sections not to be included in this Bid.

## **2. PART 2 - PROJECT MANUAL**

### **2.1. NARRATIVE CHANGES TO SPECIFICATIONS**

#### **2.1.1. Narrative changes to specification are issued as follows:**

- 2.1.1.1.** Section 03 35 11, Concrete Floor Finishes - Not in Contract.
- 2.1.1.2.** Section 04 05 11, Mortar and Masonry Grout - Not in Contract.
- 2.1.1.3.** Section 04 20 00, Unit Masonry - Not in Contract.
- 2.1.1.4.** Section 05 12 00, Structural Steel Framing - Not in Contract.
- 2.1.1.5.** Section 05 12 13, Architecturally Exposed Structural Steel Framing-Not in Contract.
- 2.1.1.6.** Section 05 31 00, Steel Decking - Not in Contract.
- 2.1.1.7.** Section 05 50 00, Metal Fabrications - Not in Contract.
- 2.1.1.8.** Section 06 10 00, Rough Carpentry - Not in Contract.
- 2.1.1.9.** Section 06 41 00, Architectural Wood Casework - Not in Contract.
- 2.1.1.10.** Section 07 54 00, Thermoplastic Membrane Roofing - Not in Contract.
- 2.1.1.11.** Section 07 62 00, Sheet Metal Flashing and Trim - Not in Contract.
- 2.1.1.12.** Section 07 92 00, Joint Sealants - Not in Contract.
- 2.1.1.13.** Section 08 06 71, Door Hardware Schedule - Not in Contract.
- 2.1.1.14.** Section 08 11 13, Hollow Metal Doors and Frames - Not in Contract.
- 2.1.1.15.** Section 08 31 00, Access Doors and Panels - Not in Contract.
- 2.1.1.16.** Section 08 33 13, Coiling Counter Doors - Not in Contract.
- 2.1.1.17.** Section 08 43 13, Aluminum-Framed Storefronts - Not in Contract.
- 2.1.1.18.** Section 08 56 59, Service and Teller Window Units - Not in Contract.
- 2.1.1.19.** Section 08 71 00, Door Hardware - Not in Contract.
- 2.1.1.20.** Section 08 80 00, Glazing - Not in Contract.
- 2.1.1.21.** Section 09 21 16, Gypsum Board Assemblies - Not in Contract.
- 2.1.1.22.** Section 09 91 13, Exterior Painting - Not in Contract.
- 2.1.1.23.** Section 09 91 23, Interior Painting - Not in Contract.
- 2.1.1.24.** Section 09 96 00, High-Performance Coatings - Not in Contract.
- 2.1.1.25.** Section 09 96 23, Graffiti-Resistant Coatings - Not in Contract.
- 2.1.1.26.** Section 10 14 00, Signage - Not in Contract.
- 2.1.1.27.** Section 10 14 53, Traffic and Parking Signage - Not in Contract.
- 2.1.1.28.** Section 10 21 13.19, Plastic Toilet Compartments - Not in Contract.
- 2.1.1.29.** Section 10 28 00, Toilet Accessories - Not in Contract.
- 2.1.1.30.** Section 11 68 33.43, Track and Field Equipment - Not in Contract.
- 2.1.1.31.** Section 11 68 43.13, Outdoor Scoreboard - Not in Contract.
- 2.1.1.32.** Section 11 68 93, Synthetic Turf Maintenance Equipment (CMAS)- Not in Contract.
- 2.1.1.33.** Section 12 36 00, Countertops - Not in Contract.
- 2.1.1.34.** Section 22 05 00, General Plumbing Requirements - Not in Contract.
- 2.1.1.35.** Section 22 05 10, General Plumbing Materials - Not in Contract.
- 2.1.1.36.** Section 22 40 00, Plumbing Fixtures - Not in Contract.
- 2.1.1.37.** Section 22 70 00, Plumbing Systems - Not in Contract.
- 2.1.1.38.** Section 23 34 23, HVAC Power Ventilation - Not in Contract.
- 2.1.1.39.** Section 26 05 26, Grounding and Bonding for Electrical Systems - Not in Contract.
- 2.1.1.40.** Section 26 05 29, Hangers and Supports for Electrical Systems - Not in Contract.
- 2.1.1.41.** Section 26 05 33.23, Surface Raceways for Electrical Systems - Not in Contract.

- 2.1.1.42. Section 26 05 39, Underfloor Raceways for Electrical Systems - Not in Contract.
- 2.1.1.43. Section 26 05 48, Vibration and Seismic Controls for Electrical Systems-Not in Contract.
- 2.1.1.44. Section 26 05 73, Power System Studies - Not in Contract.
- 2.1.1.45. Section 26 22 00, Low Voltage Transformers - Not in Contract.
- 2.1.1.46. Section 26 24 16, Panelboards - Not in Contract.
- 2.1.1.47. Section 26 27 13, Electricity Metering - Not in Contract.
- 2.1.1.48. Section 26 27 26, Wiring Devices - Not in Contract.
- 2.1.1.49. Section 26 28 16.13, Enclosed Circuit Breakers - Not in Contract.
- 2.1.1.50. Section 26 28 16.16, Enclosed Switches - Not in Contract.
- 2.1.1.51. Section 26 43 00, Surge Protective Devices - Not in Contract.
- 2.1.1.52. Section 26 51 00, Interior Lighting - Not in Contract.
- 2.1.1.53. Section 27 10 00, Structured Cabling – Not n Contract.
- 2.1.1.54. Section 28 46 00, Fire Detection and Alarm – Not in Contract.
- 2.1.1.55. Section 31 22 10, Fine Grading For Synthetic Turf Surfacing - Not in Contract.
- 2.1.1.56. Section 32 12 16.50, Asphalt Paving at Synthetic Running Track Surfacing - Not in Contract.
- 2.1.1.57. Section 32 15 41, Stabilized Decomposed Granite Surfacing - Not in Contract.
- 2.1.1.58. Section 32 16 13.50, Concrete Curbs and Flatwork at Track - Not in Contract.
- 2.1.1.59. Section 32 17 13, Parking Bumpers - Not in Contract.
- 2.1.1.60. Section 32 17 26, Tactile Warning Surfacing - Not in Contract.
- 2.1.1.61. Section 32 18 13, Synthetic Grass Surfacing (CMAS) - Not in Contract.
- 2.1.1.62. Section 32 18 23.26, Clay Brick Athletic Surfacing - Not in Contract.
- 2.1.1.63. Section 32 18 23.39, Synthetic Running Track Surfacing (CMAS) - Not in Contract.
- 2.1.1.64. Section 32 18 23\_39A, Beynon Scope Appendix - Not in Contract.
- 2.1.1.65. Section 32 18 23\_39A, D CST TRACK PROTECTION Model - Not in Contract.
- 2.1.1.66. Section 32 31 19, Decorative Metal Fences and Gates – Not in Contract.
- 2.1.1.67. Section 33 05 13, Manholes and Structures – Not in Contract.

### **3. PART 3 - DRAWINGS**

#### **3.1. CIVIL DRAWINGS ISSUED/ NOT IN CONTRACT**

- 3.1.1. The following Addendum (“AD”) Drawings, marked Delta 0, are issued:
  - 3.1.1.1. Drawing C1.0: Revised Drawing per AD0-C1, see narrative.
  - 3.1.1.2. Drawing C2.0: Not in Contract.
  - 3.1.1.3. Drawing C2.1: Not in Contract.
  - 3.1.1.4. Drawing C2.2: Not in Contract.
  - 3.1.1.5. Drawing C2.3: Not in Contract.
  - 3.1.1.6. Drawing C3.0: Not in Contract.
  - 3.1.1.7. Drawing C3.1: Not in Contract.
  - 3.1.1.8. Drawing C3.2: Not in Contract.
  - 3.1.1.9. Drawing C3.3: Not in Contract.
  - 3.1.1.10. Drawing C4.0: Not in Contract.
  - 3.1.1.11. Drawing C4.1: Not in Contract.
  - 3.1.1.12. Drawing C4.2: Not in Contract.
  - 3.1.1.13. Drawing C4.3: Not in Contract.
  - 3.1.1.14. Drawing C4.4: Not in Contract.
  - 3.1.1.15. Drawing C4.5: Not in Contract.

- 3.1.1.16. Drawing C4.6: Not in Contract.
- 3.1.1.17. Drawing C4.7: Not in Contract.
- 3.1.1.18. Drawing C5.0: Not in Contract.
- 3.1.1.19. Drawing C5.1: Not in Contract.
- 3.1.1.20. Drawing C5.2: Not in Contract.
- 3.1.1.21. Drawing C5.3: Not in Contract.
- 3.1.1.22. Drawing C5.4: Not in Contract.
- 3.1.1.23. Drawing C5.5: Not in Contract.
- 3.1.1.24. Drawing C5.6: Not in Contract.
- 3.1.1.25. Drawing C5.7: Not in Contract.
- 3.1.1.26. Drawing C6.1: Not in Contract.

3.1.2. Narrative changes to Civil Drawings are issued as follows:

- 3.1.2.1. Drawing C1.0/AD0-C1 - Area of work has been revised as shown on this sheet.

### 3.2. LANDSCAPE DRAWINGS ISSUED/NOT IN CONTRACT

3.2.1. Narrative changes to Landscape Drawings are issued as follows:

- 3.2.1.1. Drawing L1.0: Not in Contract.
- 3.2.1.2. Drawing L1.1: Not in Contract.
- 3.2.1.3. Drawing L1.2: Not in Contract.
- 3.2.1.4. Drawing L1.3: Not in Contract.
- 3.2.1.5. Drawing L3.0: Not in Contract.
- 3.2.1.6. Drawing L3.1: Not in Contract.
- 3.2.1.7. Drawing L3.2: Not in Contract.
- 3.2.1.8. Drawing L3.3: Not in Contract.
- 3.2.1.9. Drawing L4.0: Not in Contract.

### 3.3. ARCHITECTURAL DRAWINGS ISSUED/NOT IN CONTRACT

3.3.1. Narrative changes to Architectural Drawings are issued as follows:

- 3.3.1.1. Drawing G0.1.1 - Exclude items 1 thru 7 and 9 thru 12 in the 'Scope of Work'.
- 3.3.1.2. Drawing G1.0.1 - Not in Contract.
- 3.3.1.3. Drawing G1.0.2 - Not in Contract.
- 3.3.1.4. Drawing A1.1.1 - Not in Contract.
- 3.3.1.5. Drawing A1.1.2 - Exclude Details 1 & 2.
- 3.3.1.6. Drawing A1.3.2 - Exclude Details except for 8.
- 3.3.1.7. Drawing A1.3.3 - Not in Contract.
- 3.3.1.8. Drawing A1.3.4 - Not in Contract.
- 3.3.1.9. Drawing A1.3.5 - Not in Contract.
- 3.3.1.10. Drawing A2.0.1 - Not in Contract.
- 3.3.1.11. Drawing A2.0.2 - Not in Contract.
- 3.3.1.12. Drawing A5.0.1 - Not in Contract.
- 3.3.1.13. Drawing A6.0.1 - Not in Contract.
- 3.3.1.14. Drawing A6.0.2 - Not in Contract.
- 3.3.1.15. Drawing A6.1.1 - Not in Contract.
- 3.3.1.16. Drawing A6.2.1 - Not in Contract.
- 3.3.1.17. Drawing A7.0.1 - Not in Contract.

- 3.3.1.18. Drawing A8.0.1 - Not in Contract.
- 3.3.1.19. Drawing A9.0.1 - Exclude Elevation 1.
- 3.3.1.20. Drawing A9.0.2 - Not in Contract.

**3.4. STRUCTURAL DRAWINGS ISSUED/NOT IN CONTRACT**

3.4.1. Narrative changes to Structural Drawings are issued as follows:

- 3.4.1.1. Drawing S1.2 - Not in Contract.
- 3.4.1.2. Drawing S1.3 - Not in Contract.
- 3.4.1.3. Drawing S1.4 - Not in Contract.
- 3.4.1.4. Drawing S2.1 - Exclude all details except C3, for TC/Footing.
- 3.4.1.5. Drawing S3.1 - Not in Contract.
- 3.4.1.6. Drawing S4.1 - Not in Contract.

**3.5. MECHANICAL DRAWINGS ISSUED/NOT IN CONTRACT**

3.5.1. Narrative changes to Mechanical Drawings are issued as follows:

- 3.5.1.1. Drawing M-001 - Not in Contract.

**3.6. PLUMBING DRAWINGS ISSUED/NOT IN CONTRACT**

3.6.1. Narrative changes to Plumbing Drawings are issued as follows:

- 3.6.1.1. Drawing P-001 - Not in Contract.
- 3.6.1.2. Drawing P-101 - Not in Contract.

**3.7. ELECTRICAL DRAWINGS ISSUED/NOT IN CONTRACT**

3.7.1. Narrative changes to Electrical Drawings are issued as follows:

- 3.7.1.1. Drawing E-001 - Not in Contract.
- 3.7.1.2. Drawing ED-200 - Not in Contract.
- 3.7.1.3. Drawing E-200- Not in Contract.
- 3.7.1.4. Drawing E-202 - Not in Contract.
- 3.7.1.5. Drawing E-203 - Not in Contract.

**3.8. MUSCO STADIUM LIGHTING DRAWINGS ISSUED/NOT IN CONTRACT**

3.8.1. Narrative changes to **Musco Stadium Lighting** Drawings are issued as follows:

- 3.8.1.1. Drawing MT-1 - Not in Contract.
- 3.8.1.2. Drawing MS-1 - Not in Contract.
- 3.8.1.3. Drawing MS-2 - Not in Contract.

**3.9. FIELD SCOREBOARD DRAWINGS ISSUED/NOT IN CONTRACT**

3.9.1. Narrative changes to **Field Scoreboard** Drawings are issued as follows:

- 3.9.1.1. Drawing 1 - Not in Contract.
- 3.9.1.2. Drawing 2 - Not in Contract.
- 3.9.1.3. Drawing 6 - Not in Contract.

**END OF ADDENDUM #0**

**Enclosures:**

- I) New full-size Drawings Issued:
  - a) Drawings AD0-C1, Delta 0.



1. WORK SHALL BE PERFORMED ACCORDING TO THE LATEST EDITIONS OF THE STANDARD SPECIFICATIONS AND PLANS FOR PUBLIC WORKS CONSTRUCTION (GREEN BOOK & S.P.W.C.), LATEST EDITION OF CALIFORNIA BUILDING CODE AND CITY OF OXNARD BUILDING CODE REQUIREMENTS.
2. NO WORK SHALL BE STARTED WITHOUT A PRE-CONSTRUCTION MEETING WITH THE OWNER, INSPECTOR AND AOR.
3. THE CONTRACTOR SHALL PROVIDE FOR CONTRIBUTORY DRAINAGE AT ALL TIMES AND TAKE ALL NECESSARY AND PROPER PRECAUTIONS TO PROTECT EXISTING PROPERTIES AND IMPROVEMENTS FROM ANY AND ALL DAMAGE THAT MAY OCCUR FROM STORM WATER RUNOFF AND/OR DEPOSITION OF DEBRIS RESULTING FROM ANY AND ALL WORK.
4. NO REVISIONS SHALL BE MADE TO THESE PLANS WITHOUT THE APPROVAL OF THE CIVIL ENGINEER.
5. IMPORTANT NOTICE - SECTION 4216/4217 OF THE GOVERNMENT CODE REQUIRES A DIG ALERT IDENTIFICATION NUMBER BE ISSUED BEFORE ANY "PERMIT TO EXCAVATE" WILL BE VALUED FOR YOUR DIG ALERT I.D. NUMBER. CALL UNDERGROUND SERVICE ALERT TOLL FREE @ 1-800-422-4133, TWO WORKING DAYS BEFORE YOU DIG.
6. ANY IMPROVEMENTS TO BE CONSTRUCTED WITHIN PUBLIC RIGHT-OF-WAY WILL REQUIRE SEPARATE CONSTRUCTION PERMIT AND INSPECTION FROM THE GOVERNING AGENCIES. CONTRACTOR SHALL BE RESPONSIBLE FOR SECURING ALL APPLICABLE PERMITS AND PAYING ANY REQUIRED FEES.
7. FILLS SHALL BE COMPACTED THROUGHOUT TO AT LEAST 90% OF MAXIMUM DRY DENSITY AS DETERMINED BY A.S.T.M. SOIL COMPACTION TEST D 1557.
8. CONTRACTOR SHALL BE RESPONSIBLE FOR PRESERVING ALL GRADE STAKES UNTIL AUTHORIZED BY SURVEYOR TO REMOVE.
9. CONTRACTOR SHALL RESTORE LIKE FOR LIKE, TO THE SATISFACTION OF THE OWNER/ARCHITECT, ALL AREAS DAMAGED OR DISTURBED AS A RESULT OF WORK PERFORMED PURSUANT TO THESE PLANS AT HIS/HERS OWN EXPENSE.
10. FIELD DENSITY MAY BE DETERMINED BY THE NUCLEAR DENSITY METHOD (A.S.T.M. D2922 & D3017 PROVIDED NOT LESS THAN 10% OF THE REQUIRED DENSITY TESTS UNIFORMLY DISTRIBUTED ARE BY THE SAND-CONE METHOD. THE METHOD OF DETERMINING FIELD DENSITY AND LOCATION AND APPROXIMATE ELEVATION SHALL BE SHOWN IN THE COMPACTION REPORT. OTHER METHODS MAY BE USED IF RECOMMENDED BY THE SOILS ENGINEER AND APPROVED IN ADVANCE BY THE CITY ENGINEER.
11. CRUSHED AGGREGATE BASE MATERIAL SHALL CONFORM TO SUBSECTION 200-2.2 OF STANDARD SPECIFICATIONS AND SHALL BE COMPACTED TO 95% RELATIVE COMPACTION USING MECHANICAL COMPACTION EQUIPMENT.
12. NEW CONCRETE SHALL BE CLASS 520-C-2500 (310-C-17) CONFORMING WITH S.P.W.C. 201-1.1.2.
13. THE CONTRACTOR IS RESPONSIBLE FOR PROTECTING ALL EXISTING UTILITIES WHETHER SHOWN OR NOT SHOWN ON THESE DRAWINGS. THE CONTRACTOR FURTHER ASSUMES ALL LIABILITY AND RESPONSIBILITY FOR THE UTILITY PIPES, CONDUITS, OR STRUCTURES SHOWN OR NOT SHOWN ON THESE DRAWINGS. THE CONTRACTOR SHALL BE RESPONSIBLE FOR PROTECTING ALL PUBLIC AND PRIVATE PROPERTY INsofar AS IT MAY BE AFFECTED BY THESE OPERATIONS AND FOR PROTECTING, REMOVING, AND RESTORING EXISTING IMPROVEMENTS SHALL BE BORNE BY THE CONTRACTOR.
14. CONSTRUCTION CONTRACTOR AGREES THAT IN ACCORDANCE WITH GENERALLY ACCEPTED CONSTRUCTION PRACTICES, CONSTRUCTION CONTRACTOR WILL BE REQUIRED TO ASSUME SOLE AND COMPLETE RESPONSIBILITY FOR JOB SITE CONDITIONS DURING THE COURSE OF CONSTRUCTION OF THE PROJECT, INCLUDING SAFETY OF ALL PERSONS AND PROPERTY. THIS REQUIREMENT SHALL BE IN EFFECT AT ALL TIMES.
15. THE CONTRACTOR SHALL VERIFY ALL JOINT ELEVATIONS PRIOR TO THE REMOVAL OF PAVEMENT, CURB, GUTTER, SIDEWALK AND/OR SLOPE GRADING. ANY DISCREPANCIES SHALL BE REPORTED TO THE ENGINEER OF RECORD PRIOR TO REMOVALS WITHIN THE AREA OF THE DISCREPANCIES.
16. DUST SHALL BE CONTROLLED BY WATERING TO THE SATISFACTION OF THE INSPECTOR.
17. WHERE THE IRRIGATION SYSTEM IN CONFLICT WITH NEW WORK NEEDS TO BE RELOCATED OR REPLACED, CONTRACTOR SHALL COORDINATE THE WATER SHUT OFF OF ANY ELECTRICAL RELATED WORK WITH OWNER 48 HOURS PRIOR COMMENCING THE WORK.
18. ALL EXPOSED P.C.C. CORNERS SHALL BE ROUNDED WITH A 1/2" RADIUS.
19. ALL EXPORT OF MATERIAL FROM THE SITE MUST GO TO A PERMITTED SITE APPROVED BY THE BUILDING OFFICIAL OR A LEGAL DUMP SITE. RECEIPTS FOR ACCEPTANCE OF EXCESS MATERIAL BY A DUMP SITE ARE REQUIRED AND MUST BE PROVIDED TO THE BUILDING OFFICIAL UPON REQUEST.
20. CONTRACTOR TO CALCULATE HIS/HER OWN QUANTITIES FOR BIDDING PURPOSES.
21. FOR JOINTS AT NEW CURB AND SIDEWALK REFER TO S.P.P.W.C. STD. PLAN No. 112-2. ALSO SEE DETAILS ON THIS SHEET FOR ADDITIONAL INFORMATION JOINT DETAILS.
22. IF WORK IS COMMENCED DURING RAINY SEASON, CONTRACTOR SHALL SATISFY CITY OF OXNARD AND VENTURA COUNTY'S EROSION CONTROL REQUIREMENTS AND INSTALL APPROPRIATE BMPs.

**PRIVATE ENGINEER'S NOTICE TO CONTRACTOR**

THE EXISTENCE AND LOCATION OF ANY AND ALL CONDUITS, UTILITY PIPES, AND STRUCTURES SHOWN ON THIS SET OF PLANS ARE OBTAINED BASED ON AVAILABLE RECORDS AT THE TIME OF DESIGN. TO THE BEST OF OUR KNOWLEDGE, THERE ARE NO EXISTING UTILITIES WITHIN THE CONSTRUCTION LIMITS OF THIS PROJECT AT THE TIME OF DESIGN EXCEPT AS SHOWN ON THIS SET OF PLANS. THE CONTRACTOR IS REQUIRED TO TAKE DUE PRECAUTIONARY MEASURES TO PROTECT ANY AND ALL UTILITY LINES SHOWN ON THIS SET OF PLANS. THE CONTRACTOR FURTHER ASSUMES ALL LIABILITY AND RESPONSIBILITY FOR THE CONDUITS, UTILITY PIPES, AND STRUCTURES SHOWN ON THIS SET OF DRAWINGS.

CONTRACTOR AGREES THAT HE SHALL ASSUME SOLE AND COMPLETE RESPONSIBILITY FOR THE JOB SITE CONDITIONS DURING THE COURSE OF CONSTRUCTION OF THIS PROJECT. THIS STATEMENT INCLUDES THE SAFETY OF ANY AND ALL PERSONS AND PROPERTY. THE CONTRACTOR SHALL FURTHER DEFEND, INDEMNIFY, AND HOLD THE OWNER AND ENGINEER HARMLESS FROM ANY AND ALL LIABILITY, REAL OR ALLEGED, IN CONNECTION WITH THE PERFORMANCE OF WORK ON THIS PROJECT, WITH THE EXCEPTION OF LIABILITY ARISING FROM THE SOLE NEGLIGENCE OF THE OWNER OR ENGINEER.

**GENERAL NOTES FOR ON-SITE UTILITIES**

1. CONTRACTOR SHALL VERIFY ALL SITE UTILITY ROUTES, STRUCTURE LOCATIONS AND ASSOCIATED REQUIREMENTS WITH RESPECTIVE UTILITY COMPANIES BEFORE COMMENCING WORK ON THOSE UTILITIES.
2. CONTRACTOR SHALL BE RESPONSIBLE FOR PRESERVING ALL GRADE STAKES UNTIL AUTHORIZED BY SURVEYOR TO REMOVE.
3. INDIVIDUAL PIPE FITTINGS ARE NOT CALLED OUT; CONTRACTOR SHALL PROVIDE AND INSTALL ALL NECESSARY FITTINGS AS REQUIRED TO COMPLETE THIS PROJECT. PIPE LENGTHS SHOWN ARE APPROXIMATE.
4. RESTORATION/REPAIR: CONTRACTOR SHALL RESTORE/REPAIR ALL AREAS DAMAGED OR DISTURBED AS A RESULT OF ALL WORK PERFORMED PURSUANT TO THESE PLANS. SUCH AREAS INCLUDE, BUT ARE NOT LIMITED TO, CURB AND GUTTER, A.C. PAVEMENT, CONCRETE, STRIPING, LANDSCAPING, AND UTILITIES. RESTORATION/REPAIR SHALL INCLUDE, BUT IS NOT LIMITED TO, MATCHING A.C. AND CONCRETE SECTIONS AND TEXTURE, MATCHING FINISH AS APPLICABLE, ALL TO THE SATISFACTION OF THE DISTRICT.
5. ADDITIONAL MATERIALS: CONTRACTOR SHALL PROVIDE ALL NECESSARY MATERIALS AND LABOR, SUBJECT TO THE APPROVAL OF THE DISTRICT AND ARCHITECT/ENGINEER, NOT SPECIFICALLY DESCRIBED IN THE CONSTRUCTION NOTES BUT REQUIRED FOR COMPLETE AND PROPER INSTALLATION OF THIS WORK.
6. ALL MATERIALS REMOVED SHALL BE TAKEN OFF SCHOOL PROPERTY BY CONTRACTOR AND DISPOSED OF IN ACCORDANCE WITH APPLICABLE CODES UNLESS DIRECTED BY OWNER TO BE SALVAGED.
7. CONTRACTOR TO POTHOLE AND VERIFY THE SIZE, MATERIAL AND INVERT ELEVATION OF EXISTING UTILITY AND VERIFY THAT THE CONNECTION CAN BE MADE AS SHOWN ON THE PLAN. IN THE EVENT OF A DISCREPANCY, NOTIFY THE OWNER/PROJECT MANAGER OF THE FIELD FINDINGS 7 DAYS PRIOR TO THE CONSTRUCTION DATE FOR ALTERNATIVE RESOLUTION.

**CONTRACTOR TO INCLUDE IN THEIR BID (SWPPP)**

IT WILL BE THE RESPONSIBILITY OF THE CONTRACTOR TO PREPARE SWPPP; SUBMIT IT TO THE STATE WATER QUALITY BOARD, OBTAIN NOI (NOTICE OF INTENT), AND PAY THE NECESSARY FEES FOR THE PERMIT. SWPPP MUST BE PREPARED BY A CERTIFIED OSD.

IT WILL ALSO BE THE CONTRACTOR'S RESPONSIBILITY TO OBTAIN A CERTIFIED "OSP" FOR SWPPP OBSERVATIONS AND FILING ALL NECESSARY REPORTS THROUGH "SMART" WITH THE STATE WATER QUALITY BOARD THROUGHOUT THE LIFE OF THE PROJECT TILL IT IS COMPLETED. CONTRACTOR'S "OSP" SHALL FILE THE NOI (NOTICE OF INTENT).



**LEGEND**

FS	FINISH SURFACE ELEVATION
TC	END OF CURB ELEVATION
TS	TOP OF CONCRETE SLAB ELEVATION
XX.XX	PROPOSED SPOT ELEVATION
(XX.XX)	EXISTING SPOT ELEVATION
—	CMU WALL
—	EXISTING FENCE
—	NEW C.L. FENCE
CONC.	CONCRETE
G.B.	GRADE BREAK
ESW	EDGE OF SIDEWALK
DWY	DRIVEWAY
C&G	CURB & GUTTER
H.P.	HIGH POINT
N.G.	NATURAL GROUND
S.P.P.W.C.	STANDARD PLANS FOR PUBLIC WORKS CONSTRUCTION
S.S.P.W.C.	STANDARD SPECIFICATIONS FOR PUBLIC WORKS CONSTRUCTION
C.F.	CURB FACE
ELEV.	ELEVATION
EX.	EXISTING
BCR.	BEGIN CURB RETURN
ECR.	END CURB RETURN
A.P.	ANGLE POINT
(X)	FURNISH AND INSTALL/CONSTRUCT, DEMOLISH, REMOVE AND REPLACE, OR RELOCATE, AS INDICATED.
(XX.XX)	NEW SLOPE
(XX.XX)	EXISTING SLOPE
FL	FLOW LINE
T.B.M.	TEMPORARY BENCH MARK
CONC.	CONCRETE PAVEMENT
A.C.	ASPHALT CONCRETE PAVING
(N)	NEW
T.B.M.	TEMPORARY BENCH MARK
F.F.	FINISH FLOOR
A.F.F.	ABOVE FINISH FLOOR
A.P.	ANGLE POINT
EG	EDGE OF GUTTER
CLR.	CLEAR
SCD	SEWER CLEAN-OUT
SMH	SEWER MANHOLE
S.J.	SAWJUT JOINT
E.J.	EXPANSION JOINT
C.J.	CONTROL JOINT
D.I.	DRAIN INLET
SCD	SEWER CLEAN-OUT
EPB	ELECTRICAL PULL BOX
WV	WATER VALVE
P.A.	PLANTING AREA

**BASIS OF BEARING**



N89°55'34"W BEING THE CENTERLINE OF GARY DRIVE PER MAP RECORDED IN BOOK 78, PAGES 34 THROUGH 37, OF MISCELLANEOUS RECORDS, IN THE OFFICE OF THE COUNTY RECORDER OF VENTURA COUNTY, STATE OF CALIFORNIA.

**BENCHMARK**

CITY OF OXNARD GARY 2000

ELEVATION: 9.732 (NAVD 88)

DESCRIPTION: BRASS DISK STAMPED "GARY 2000" SET ON TOP OF CURB AT THE SOUTHWEST CORNER OF THE INTERSECTION OF ROSE AVENUE AND GARY DRIVE. THE DISK IS 5.5 FEET SOUTH OF THE SOUTHERLY CURB RETURN (ECR).



CAMPUS LOCATION MAP: WORK AREAS

**AGENCY REVIEW**

IDENTIFICATION STAMP  
DIV. OF THE STATE ARCHITECT  
APP. 03-120287 INC.  
REVIEWED FOR  
SS  FLS  ACS   
DATE: 03/09/2020

**LITTLE**  
DIVERSIFIED ARCHITECTURAL CONSULTING

1300 Dove Street, Suite 100  
Newport Beach, CA. 92660  
T: 949.698.1400

www.littleonline.com

This drawing and the design shown are the property of Little Diversified Architectural Consulting. The reproduction, copying or other use of this drawing without their written consent is prohibited and any engagement will be subject to legal action.

© Little 2019

**CLIENT NAME**  
OXNARD UNION  
HIGH SCHOOL  
DISTRICT

**PROJECT NAME**  
CHANNEL ISLANDS HIGH SCHOOL  
TRACK & FIELD IMPROVEMENTS

1400 RAIDERS WAY,  
OXNARD, CA. 93033

**CONSULTANT**

**SEAL**

**ISSUE FOR**  
DSA SUBMITTAL SET

**ISSUE DATE**  
03/09/20

NO.	REASON	DATE

**PROJECT TEAM**  
PRINCIPAL IN CHARGE  
BB  
PROJECT MANAGER  
BB  
DESIGN TEAM  
SA, ML, VS, AT  
PROJECT NAME  
CHANNEL ISLANDS HIGH SCHOOL  
TRACK & FIELD IMPROVEMENTS +  
GATEWAY IMPROVEMENTS

**PROJECT NO.**  
6121235305

**SHEET TITLE**  
COVER SHEET -  
NOTES & INDEX MAP

**SHEET NUMBER**  
C1.0 **AD0-C1**